

DECLARATION OF CONFORMITY

MAXVU Series (And corresponding branded products)

This product is manufactured at the premises of West Control Solutions, The Hyde Business Park, Brighton, East Sussex, BN2 4JU, England, UK

This declaration of conformity is issued under the sole responsibility of the manufacturer.

The objects of this declaration are the products identified using the model numbers derived from the tables listed below.

The objects of this declaration are in conformity with the following European Union harmonisation legislation:

2014/30/EU Electromagnetic Compatibility

2014/35/EU Low Voltage Directive

2011/65/EU Restriction of Hazardous Substances in Electrical and Electronic Equipment and subsequent amendment 2015/863/EU

The assessment of conformity has been made using the standards route to compliance. The standards this product is compliant with are listed below: -

EN 61326-1:2013 Electrical equipment for measurement, control and laboratory use — EMC Requirements — Part 1: General Requirements

FCC Title 47 Chapter 1A Part 15B RADIO FREQUENCY DEVICES

FCC Title 47 Chapter 1A Part 18 INDUSTRIAL, SCIENTIFIC, AND MEDICAL EQUIPMENT

EN55011:2009 + A1:2010 Industrial, scientific and medical equipment – Radio Frequency disturbance characteristics – Limits and methods of measurement

This product has been evaluated as Class A equipment suitable for operation in Industrial Locations against this standard.

WARNING

This is a Class A product. In a domestic environment this product may cause radio interference in which case the user may be required to take adequate measures.

UL 61010-1 Edition 3, Safety requirements for electrical equipment for measurement, control and laboratory use; Part 1: General Requirements

BS EN IEC 63000:2018, Technical documentation for the assessment of electrical and electronic products with respect to the restriction of hazardous substances.

This declaration is made for and on behalf of Fortive by Paul Barber, who has been designated as the responsible person for the purpose of the regulations.

Signature:

Date of Issue:

13 January 2021

(Paul Barber)

Model Code	MV	xx	x	x	xxx	x	2	x	x	0
Model Type										
1/16 DIN		16								
1/8 DIN		08								
Variant										
Standard			0							
Extrusion			E							
Supply Voltage										
100-240V AC				M						
Low volts				L						
Output Configuration										
Out 1	Out 2	Out3								
SSR	None	None				A00				
Relay	None	None				R00				
SSR	SSR	None				AA0				
SSR	Relay	None				AR0				
Relay	Relay	None				RR0				
SSR	SSR	SSR				AAA				
SSR	SSR	Relay				AAR				
SSR	Relay	Relay				ARR				
Relay	Relay	Relay				RRR				
Option A										
Not fitted							0			
RS485							C			
Display										
Upper - Red, Lower - Green							2			
Manual										
No Manual								0		
English								1		
French								2		
German								3		
Italian								4		
Spanish								5		
Mandarin Chinese								6		
EU Languages								9		
Certification										
CE									0	
CE, UL									U	
No Approvals									X	



West Control Solutions
 The Hyde Business Park,
 Brighton BN2 4JU, UK

Web: www.west-cs.com
e-mail: info@west-cs.com
Tel: +44 (0) 1273 606271
Fax: +44 (0) 1273 609990

Packing Options (for future use)										
Single pack with concise manual										0